# **T3 Modules**

# **User's Manual**



T3-8AI8AO: 8 Universal Input 8 analog output



T3-4AO: 10 Universal Inputs 4 Analog Outputs 8 dry-contact relay outputs



T3-32I: 32 Universal Inputs



T3-6CT: 10 Universal Inputs 6 AC Current Inputs (6 CTs) 5 Relay Outputs



T3-8I13O: 8 Universal Inputs 13 relay outputs



T3-PT10: 10 Universal PT100 Inputs

# **1** Introduction

#### 1.1 About this manual

The purpose of this manual is to provide instructions to simply and quickly install and operate the T3 Module equipment. The manual begins with a general description of the product followed by the instructions for correct hardware installation. Its configuration and operation of the device are described in detail later in the manual.

# **1.2 General Description**

The T3 Series are general purpose input / ouput modules for building integrators. Available in several input/output configurations, the T3 Series modules provide convenient termination for field devices and interfacing to your HVAC, lighting, temperature sensors, and other typical building automation applications. Each of the analog inputs can be jumper configured for signals of either 0-5V, 0-20mA, or dry contact. The outputs are available in dry contacts 1amp/output, 0-10V analog, and PNP sinking. The modules are slave devices that can be easily controlled via the RS485 serial interface using the industry standard Modbus Protocol.

#### Highlights:

- Surge-Protected Analog Inputs with 10-bit Resolution
- Outputs can Individually be switched to ON, OFF, AUTO
- High Impact Plastic Enclosure provides durability in commercial environments
- Standard Modbus Protocol allows for up to 254 unique devices on one RS485 Network

#### 1.3 Technical Data

T3-8AIAO	8 Analog Outputs @ 0-10VDC 200mA total, 8 Analog Inputs @ 0-5V, 0-20mA, Dry
T3-32I	32 Analog Inputs @0-5V, 0-10V, 0-20mA, Dry
T3-8I13O	13 Dry-contact relay outputs x 2amps @120V, 8 analog inputs @0-5V, 0-20mA, dry
T3-4AO	8 dry-contact relay outputs x2amps @120V, 4 analog outputs @0-10V, 10 analog input @ 0-5V, 0-10V, 0-20mA, dry
T3-6CT	T3 series, general purpose 10 Analog Inputs, 6 Digital Inputs, 5 Relay Outputs, RS485 network
T3-PT10	T3 series, 10 Universal PT100 Input module, with 2-3 or 4 wire connections, RS485 network
Operating Temperature	-30~70°C (-22~158°F)
Supply Voltage	12~24VAC/DC ±10%, 50-60Hz
Power Consumption	100mA at 12VDC
Relay Contacts Rating	Max 2A
Ambient Humidity	10-90 %Rh
Plastic Housing	Flammability Rating UL 94V0 File E194560
Enclosure Rating	IP31
Temperature Sensor	10K Thermistor ±0.5°C
Color	White/Off-White

T3 Model	Universa	I Inputs	AO	DO
	0-5V 0-20mA	0-5V 0-10V 0-20mA		
T3-8AI8AO	8		8	
T3-32I		32		
T3-8I13O	8			13 Relay 120VAC, 2A
T3-4AO		10	4	13 Relay 120VAC, 2A
T3-6CT	10 Univers (6CTs), 5 F	sal Inputs Relay Outp	, 6 AC uts	Current Inputs
T3-PT10	10 x PT100	) inputs, 2-	-3-4 wire	)

Dimensions: 115(L) x 90(W) x 40mm(H)



# T3-4AO

# Description

The T3 Series are general purpose input / output modules for building integrators. Available in several input/output configurations, the T3 Series modules provide convenient termination for field devices and interfacing to your HVAC, lighting, temperature sensors, and other typical building automation applications. Each of the analog inputs can be jumper configured for signals of either 0-5V, 0-20mA, or dry contact. The outputs are available in dry contacts 2amp/output, 0-10V analog, and PNP sinking. The modules are slave devices that can be easily controlled via the RS485 serial inter face using the industry standard Modbus Protocol.

#### Highlights:

- Surge-Protected Analog Inputs with 10-bit resolution.
- Outputs can individually be switched to ON, OFF or AUTO.
- High Impact Plastic Enclosure Provides durability in commercial environments.
- Standard modbus protocol allows for up to 254 unique devices on one RS485 network.



# Special Features

The T3-4AO has a few additional features which the other T3 series do not have due to a more advanced CPU. For example the faster scan rates for the inputs In on/off mode, inputs 3 through 10 can count pulses up to 1 khz on each channel. In analog mode, inputs 3 thru 10 are 12 bits compared to the previous 12 bits, inputs 1 and 2 remain as 8 bits and slower at pulse counting.

For developers there is a significant improvement with the larger rom and ram space: 128k versus 64k for the flash space and 3k ram versus 1k of ram space compared to the earlier models. This gives more room for developers to add features such as Bacnet, PLC type logic, logging, etc. Secondly there's an additional serial port, currently the port is unused but developers will be able to use the second port to manage a subnet of local sensors, keypads and displays for example, or use it in repeater mode to extend and isolate the RS485 main network.

#### **Technical Data**

T3-4AO	8 Dry-Contact Relay Outputs x 2amps @120V, 4 Analog Outputs @0-10V, 10 Analog Input @ 0-5V, 0-10V, 0-20mA, Dry
Operating Temperature	-30~70°C (-22~158°F)
Supply Voltage	12~24VAC/DC ±10%, 50-60Hz
Power Consumption	100mA at 12~24VAC/DC
Relay Contacts Rating	Max 2A
Ambient Humidity	10-90 %Rh
Plastic Housing	Flammability Rating UL 94V0 File E194560
Enclosure Rating	IP31
Temperature Sensor	10K Thermistor ±0.5°C
Color	White/Off-white
Dimensions	115 x 90 x 40mm

# Description

The PT-10 is a low-cost, high-accuracy digital thermometer read out designed with 10 Univeral PT100 Inputs. Its combination of features makes this instrument well suited for a wide variety of industrial applications.

#### Highlights:

- 10 Universal PT 100 Inputs
- Serial RS 485 Standard
- Light-weight and Compact
- Usable with 2, 3 or 4 Wire connections



# **Technical Data**

Resistance Range	$0\Omega$ to $400\Omega$ , auto-ranging	
Resistance Accuracy, One year	0Ω to 20Ω: 0.01Ω 20Ω to 400Ω: 0.05% (15 ppm) of reading	
Resistance Accuracy, Short-Term	0Ω to 30Ω: 0.005Ω 30Ω to 400Ω: 0.03% (15 ppm) of reading	
Resistance Resolution	Adjustable to .001 $\Omega$ (See Register List)	
Temperature Range	-200°C to 962°C (-328°F to 1764°F)	
Temperature Coefficient of Resistance	10 ppm/°C	
Temperature Accuracy	0.01°C	
Temperature Resolution	Adjustable to .001°C (See Register List)	
Probe Connection	4-wire with shield, 5-pin DIN connector (2 & 3 - Wire Connection also possible)	
Maximum Acceptable Lead Resistance	100Ω	
Probe Excitation Current	PRT 1 mA	
Communications	RS-485 Serial Standard	
AC Power	12~24 VAC/DC ±10, 50/60 Hz, 10 W, Nominal, 1A Maximum	

# **Environmental Conditions**

Ambient Temperature Range	0-55°C (32-131°F); [Full Accuracy 16-30°C (61-86°F)]	
Ambient Relative Humidity	Maximum 80% for Temperature < 31°C, Decreasing Linearly to 50% at 40°C	
Pressure	75kPa - 106kPa	
Main Voltage within ±10% of Nominal		
Vibrations Should be Minimized		
Altitude Less than 2,000 Meters		
Indoor Use Only		

# Wiring Diagram



T3-PT10 Terminal Block Diagram

T3-CT connect with current sensor



# 1.5 Standard Operation

# 1.5.1 Inputs

Each input of a T3 Module can be jumper-configured in 1 of 3 ways:

- 0-5V Signal
- 0-20mA Signal

•Dry Contact, Thermistor

The value of each input is stored as a 10-bit number in the respective modbus register. The registers addresses are as follows:

T3 Model	Number of Inputs	Register Addresses
T3-8AIAO	8	108-115
T3-32I	32	100-131
T3-8I13O	8	118-133
T3-4AO	10	190-199

Table1: Input Register Addresses

A 5V, or 20mA, would give a reading of 1024. Each input has a corresponding LED which will light up if the value of the input is greater than 512. For more info on reading the input registers, see the section on Serial Communications.

T3-4AO is 5V, or 20mA, and would give a reading of 4095. Each input has a corresponding LED which will light up if the value of the input is greater than 2047. For more info on reading the input registers, see the section on Serial Communications.

# 1.5.2 Outputs

The state of each output is determined by its corresponding switch position. The switches have 3 states – 'hand', 'off', and 'auto'. When switched to 'hand', the corresponding output will be switched on - 10V for analog, contacts closed off from the relay, or 0V for sinking outputs. When switched to 'off', the output will be set to 0V for analog, open contact for relay, or open circuit for sinking outputs. When switched to 'auto', Analog outputs will be set to the level stored in the corresponding MODBUS output registers. For Digital or Sinking outputs, a register value 0 is deactivate and register value 1000 is activated.

The output registers are as follows:

T3 Model	Number of Outputs	Register Addresses
T3-8AIAO	8	100-107
T3-32I	0	
T3-8I13O	13	100-112
T3-4AO	12	100-111

#### Table 2: Output Register Addresses

These registers can be changed using the RS485 serial interface. For analog outputs, a 0 corresponds to 0V. Likewise, a 1024 corresponds to 10V. For relay or sinking outputs, the output will be activated by any number greater than 512. The output registers are stored in RAM, thus the contents of each register will be lost upon power-off. Each output has a corresponding LED which will light up if the value of the output is greater than 512 (5V). For more info on writing the output registers, see the section on Serial Communications.

# 1.5.3 Analog Output Calibration

The T3-8IO-A has an output calibration feature that allows for an adjustment of +/- 1.28V. Calibration is controlled via the calibration register located at registery address 13. By default, this is 128, which corresponds to 0V calibration. A value of 0 would give a -1.28V offset. A value of 255 would give a +1.28V offset. It is recommended that the calibration be determined while the output is set to 5V. The calibration value is located in flash memory and will be restored upon power-up.

#### 1.5.4 Baudrate

All T3-Modules have adjustable Baudrates set by MODBUS registery 15. By default baud is set to 19.2kbps. Value 1 will set the baud to 19200 bps.

Value 0 will set the baud to 9600 bps.

#### 1.6 Accessing T3 Series Registers Via Serial Communications

The T3-Modules have a built-in serial interface for communication over an RS485 Network. Communication is currently implemented using Modbus Protocol. However, future versions of the T3-Modules will work with both BACnet and TCP/IP Protocols. For detailed information on Modbus Protocol, see the chapter entitled Modbus Serial Communications.

#### **1.6.1** Connecting the T3 module to a computer

The T3-Modules connect to a computer serial port via the RS485 interface. Figure 14 shows how the T3-Module should be connected to the serial port of a PC.



# T3- COMPUTER CONNECTION

# How to set up pulse counting features

# 1.T3-4AO

You can change the number to choose which chanel as pulse. For example, when you need the 3 chanel as pulse chanel, you can change 6=Pulse Input to 3= Pulse Input.

Address	T3-4AO		
	Bytes	Details	
200	1	Range Setting for each input.	
201	1	200 correspond to input1,	
202	1	201 correspond to input2, etc.	
203	1	0 = raw data,	
204	1	1 = 10K Celsius,	
205	1	2 = 10K Fahrenheit,	
206	1	3 = 0-100%	
207	1	4 = ON/OFF,	
208	1	5 = OFF/ON	
209	1	6 = Pulse Input	
		7 = Lighting Control 8 = type3 10K Celsius, 9=TYPE 3 10K Fahren- heit, 10 = No use, 11 =V0_5, 12= V0_10, 13 = I0_20ma.	

# 2.T3-8I13O

You can change the number to choose which chanel as pulse. For example, when you need the 3 chanel as pulse chanel, you can change 6=Pulse Input to 3= Pulse Input.

Address	T3-8I13O		
	Bytes	Details	
183	1	Range Setting for each input.	
184	1	183 correspond to input1,	
185	1	184 correspond to input2, etc.	
186	1	0 = raw data,	
187	1	1 = 10K Celsius,	
188	1	2 = 10K Fahrenheit,	
189	1	3 = 0-100%	
190	1	4 = ON/OFF,	
		5 = OFF/ON	
		6 = Pulse Input	
		7 = Lighting Control 8 = type3 10K Celsius, 9=TYPE 3 10K Fahren- heit,10 = No use, 11 =V0_5,12= V0_10,13 = I0_20ma.	

# 3.T3-28IN

You can change it by jumper.

Address		T3-8I13O
	Bytes	Details
130	2	Pulse input1 high byte
131	2	Pulse input1 low byte
132	2	Pulse input2 high byte
133	2	Pulse input2 low byte
134	2	Reset Pulse1 number
135	2	Reset Pulse2 number

# 4. Pulse speed detail for all T3 Module

Module	Frequency
T3-4AO	<1KHZ
T3-8I13O	<10HZ
T3-28IN	≤10KHZ

# 1.6.2 List of registers in the T3-8AIAO

Note: When using the Modbus Poll software, addressing should be set to "Protocol Addresses (Base 0)" under the "Display" menu.

Address	Bytes	Register and Description	
0 to 3	4	Serial Number, 4 byte value	
4	1	EEPROM Hardware Version Number	
5	1	Firmware Version Number	
6	1	ADDRESS. Modbus Device Address	
7	1	Product Model	
8	1	Hardware Revision	
9	1	PIC Version Number	
13	1	Calibration Registery – used to calibrate the outputs.	
15	1	Baudrate Setting: 0 will set 9600bps, 1 will set 19200bps	
22	1	Heartbeat register: It will increase every min from 0 to 255 and cycle the roution	
100	2	Output 1 Register	
101	2	Output 2 Register	
102	2	Output 3 Register	
103	2	Output 4 Register	
104	2	Output 5 Register	
105	2	Output 6 Register	
106	2	Output 7 Register	
107	2	Output 8 Register	
108	2	Input 1 Register	
109	2	Input 2 Register	
110	2	Input 3 Register	
111	2	Input 4 Register	
112	2	Input 5 Register	
113	2	Input 6 Register	
114	2	Input 7 Register	
115	2	Input 8 Register	
116	2	Register 116, 117 and 118 hold the position information on each of the hand-off-auto switches on the T3 modules	
117	2	Each switch has three positions and therefore each switch requires 2 bits to hold the state. Modbus registers are 16 bits wide so we can hold the status of 8 switches in register 116, the next 8 are held in register 117	
118	2	and so on, up to the number of switches on the particular T3 module. The switch states are as follows: 00= Off, the switch is in the center position 10= Auto, the switch is positioned towards the terminal block 01= Hand, manually on. The switch is positioned towards the center of the module (away from the terminal block).	
119 - 125	1	Range for each Input, 118 Correspond to ch1.0 = raw data,1 = 10K Celsius, 2 = 10K Fahrenheit ,3 = 0 - 100%,4 = ON/OFF, 5 = OFF/ON	
126-133	1	Filter Coefficient for Input 1 to 8, value is 0 through 100, default is 20.	
Exam	ple: Re Re The	gistery 118 reads 5 (hex 05) gistery 119 reads 138 (hex 8A) e Pulse Count for Channel 1 is then 1418 pulse (hex 058A)	
Writing to registery 134 will clear registeries 118 and 119. Subsequent registeries 135 to 138 are optional memory to			

**1.6.3 Lits of Registers in the T3-32I** Note: Addressing should be set to "Protocol Addresses (Base 0)" under the "Display" menu.

Address	Bytes	Register and Description						
0 to 3	4	Serial Number, 4 byte value						
4	1	EEPROM Hardware Version Number						
5	1	Firmware Version Number						
6	1	ADDRESS. Modbus Device Address						
7	1	Product Model						
8	1	Hardware Revision						
9	1	PIC Version Number						
13	1	Calibration Register – used to calibrate the outputs.						
15	1	audrate Setting: 0 will set 9600bps, 1 will set 19200bps						
22	1	leartbeat register: It will increase every min from 0 to 255 and cycle the roution						
100	2	Input 1 Register						
101	2	Input 2 Register						
102	2	Input 3 Register						
103	2	Input 4 Register						
104	2	Input 5 Register						
105	2	Input 6 Register						
106	2	Input 7 Register						
107	2	Input 8 Register						
108	2	ut 9 Register						
109	2	put 10 Register						
110	2	put 11 Register						
111	2	put 12 Register						
112	2	Input 13 Register						
113	2	Input 14 Register						
114	2	Input 15 Register						
115	2	Input 16 Register						
116	2	Register 116 , 117 and 118 hold the position information on each of the hand-off-auto switches on the T3 modules Each switch has three positions and therefore each switch requires 2 bits to hold the state.						
117	2	<ul> <li>addus registers are 16 bits wide so we can hold the status of 8 switches in register 116, the next 8 are held in register 117 and so on, up to the mber of switches on the particular T3 module.</li> <li>e switch states are as follows:</li> <li>= off , the switch is in the center position</li> <li>= auto, the switch is positioned towards the terminal block</li> <li>= hand, manually on. The switch is positioned towards the center of the module (away from the terminal block).</li> </ul>						
119	2	Input 20 Register						
120	2	Input 21 Register						
121	2	Input 22 Register						
122	2	Input 23 Register						
123	2	Input 24 Register						
124	2	Input 25 Register						
125	2	Input 26 Register						
126	2	Input 27 Register						
127	2	Input 28 Register						
128	2	Input 29 Register						
129	2	Input 30 Register						
130	2	Input 31 Register						
131	2	Input 32 Register						
228-259	1	Range for each input, 228 correspond to ch1.0 = raw data, 1 = 10K Celsius, 2 = 10K Fahrenheit ,3 = 0 - 100%,4 = ON/OFF, 5 = OFF/ON						
260-291	1	Filter coefficient for input 1 to 32, value is 0 through 100, default is 20.						

1.6.4 List of Registers in the T3-8I13O

Address	Bytes	Register and Description						
0 to 3	4	Serial Number, 4 byte value						
4	1	EEPROM Hardware Version Number						
5	1	Firmware Version Number						
6	1	ADDRESS. Modbus Device Address						
7	1	Product Model						
8	1	Hardware Revision						
9	1	PIC Version Number						
13	1	Calibration Register – used to calibrate the outputs.						
15	1	Baudrate Setting: 0 will set 9600bps, 1 will set 19200bps						
16-21	1	rved						
22	1	Heartbeat register: It will increase every min from 0 to 255 and cycle the roution						
23-99	1	Reserved						
100	2	Output 1 Register						
101	2	Output 2 Register						
102	2	Output 3 Register						
103	2	Output 4 Register						
104	2	Output 5 Register						
105	2	Output 6 Register						
106	2	Output 7 Register						
107	2	Output 8 Register						
108	2	Output 9 Register						
109	2	Output 10 Register						
110	2	out 11 Register						
111	2	put 12 Register						
112	2	Output 13 Register						
113 - 115	1	Reserved						
116	2	egister 116 and 117 hold the position information on each of the hand-off-auto switches on the T3 modules ach switch has three positions and therefore each switch requires 2 bits to hold the state. odbus registers are 16 bits wide so we can hold the status of 8 switches in register 116, the next 8 are held in register 117 and so on, up to the umber of switchs on the particular T3 module. he switch states are as follows: D= off , the switch is in the center position D=auto, the switch is positioned towards the terminal block 1= hand, manually on. The switch is positioned towards the center of the module (away from the terminal block).						
118	2	IN1 high word						
119	2	IN1 low word						
120	2	IN2 high word						
121	2	IN2 low word						
122	2	N3 high word						
123	2	IN3 low word						
124	2	IN4 high word						
125	2	IN4 low word						
126	2	IN5 high word						
127	2	IN5 low word						
128	2	IN6 high word						
129	2	IN6 low word						
130	2	IN7 high word						
131	2	N7 low word						
132	2	IN8 high word						
133	2	IN8 low word						

# 1.6.4 List of Registers in the T3-8I13O (continued)

Address	Bytes	Register and Description							
134-138	5	Date stamp of Channel 1: Year, Month, Day, Hour, Minute respectively.							
139-143	5	Date stamp of Channel 2: Year, Month, Day, Hour, Minute respectively							
144-148	5	ate stamp of Channel 3: Year, Month, Day, Hour, Minute respectively.							
149-153	5	ate stamp of Channel 4: Year, Month, Day, Hour, Minute respectively.							
154-158	5	ate stamp of Channel 5: Year, Month, Day, Hour, Minute respectively.							
159-163	5	Date stamp of Channel 6: Year, Month, Day, Hour, Minute respectively.							
164-168	5	Date stamp of Channel 7: Year, Month, Day, Hour, Minute respectively.							
169-173	5	Date stamp of Channel 8: Year, Month, Day, Hour, Minute respectively.							
174	1	are							
175-182	2	Analog reading from each channel, whatever the channel be set as analog or pulse mode. 175 correspond to ch1							
183-190	1	Range for each input, 183 correspond to ch1.0 = raw data, 1 = 10K Celsius, 2 = 10K Fahrenheit ,3 = 0 - 100%,4 = ON/OFF, 5 = OFF/ON							
191	1	Filter coefficient for input 1, 0 through 100, default is 20.							
192	1	Filter coefficient for input 2, 0 through 100, default is 20.							
193	1	Filter coefficient for input 3, 0 through 100, default is 20.							
194	1	Filter coefficient for input 4, 0 through 100, default is 20.							
195	1	Filter coefficient for input 5, 0 through 100, default is 20.							
196	1	Filter coefficient for input 6, 0 through 100, default is 20.							
197	1	Filter coefficient for input 7, 0 through 100, default is 20.							
198	1	Filter coefficient for input 8, 0 through 100, default is 20.							
199	1	er for input 1, how long time the lighting control take over the outputs							
200	1	er for input 2, how long time the lighting control take over the outputs							
201	1	Timer for input 3, how long time the lighting control take over the outputs							
202	1	Timer for input 4, how long time the lighting control take over the outputs							
203	1	Timer for input 5, how long time the lighting control take over the outputs							
204	1	Timer for input 6, how long time the lighting control take over the outputs							
205	1	Timer for input 7, how long time the lighting control take over the outputs							
206	1	Timer for input 8, how long time the lighting control take over the outputs							
207	1	put1 timer Left, how much time left for the lighting control							
208	1	nput 2 timer Left, how much time left for the lighting control							
209	1	Input 3 timer Left, how much time left for the lighting control							
210	1	Input 4 timer Left, how much time left for the lighting control							
211	1	Input 5 timer Left, how much time left for the lighting control							
212	1	Input 6 timer Left, how much time left for the lighting control							
213	1	Input 7 timer Left, how much time left for the lighting control							
214	1	Input 8 timer Left, how much time left for the lighting control							
215	1	light control disable/enable, each bit correspond to one output,output1 correspond to least significant bit, 0 = disable,1 = enable							
216	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
217	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
218	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
219	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
220	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
221	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
222	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							
223	1	Select which input as lighting control trigger, 0 = disable lighting control,1= input1,2=input2							

# 1.6.4 List of Registers in the T3-8I13O (continued)

Address	Bytes	Register and Description
224	1	Select which input as lighting control trigger,0 = disable lighting control,1= input1,2=input2
225	1	Select which input as lighting control trigger,0 = disable lighting control,1= input1,2=input2
226	1	Select which input as lighting control trigger,0 = disable lighting control,1= input1,2=input2
227	1	Select which input as lighting control trigger,0 = disable lighting control,1= input1,2=input2
228	1	Select which input as lighting control trigger,0 = disable lighting control,1= input1,2=input2

# 1.6.6 List of Registers in the T3-4AO

Address	Bytes	Register and Description						
0 - 3	4	Serial Number 4 Bytes value						
4	1	Firmware Version, low byte						
5	1	Firmware Version, hi byte						
6	1	odbus Device Address						
7	1	roduct Model						
8	1	Hardware Revision						
9	1	PIC Version Number						
10-12		eserved						
13	1	Calibration Register-Used to calibrate the outputs						
14		Reserved						
15	1	Baudrate Setting: 0 = 9600bps, 1 = 19200bps						
16	1	Firmware Update Register, used to show the status of firmware updates						
17-21		Reserved						
22	1	Heartbeat register: It will increase every min from 0 to 255 and cycle the roution						
23-99		Reserved						
100	2	Output 1 Register						
101	2	Output 2 Register						
102	2	itput 3 Register						
103	2	Itput 4 Register						
104	2	Output 5 Register						
105	2	Output 6 Register						
106	2	Output 7 Register						
107	2	Output 8 Register						
108	2	Output 9 Register						
109	2	Output 10 Register						
110	2	Output 11 Register						
111	2	Output 12 Register						
112	0	Reserved						
113	0	Reserved						
114	0	Reserved						
115	0	Reserved						
116	2	Register 116, 117 and 118 hold the position information on each of the hand-off-auto switches on the T3 modules						
117	2	Modbus registers are 16 bits wide so it can hold the status of 8 switches in register 116, the next 8 are held in register 117 and so on, up to the						
118	2	number of switches on the particular T3-Module. The switch states are as follows: • 00= OFF, the switch is in the center position • 10= AUTO, the switch is positioned towards the terminal block • 01= HAND, manually on. The switch is positioned towards the center of the module (away from the terminal block).						
119	2	Input 1 Register, high word						
120	2	Input 1 Register, low word						

# 1.6.5 List of Registers in the T3-4AO (Continued)

Address	Bytes	Register and Description						
121	2	Input 2 Register, high word						
122	2	Input 2 Register, low word						
123	2	out 3 Register, high word						
124	2	Input 3 Register, low word						
125	2	Input 4 Register, high word						
126	2	Input 4 Register, low word						
127	2	Input 5 Register, high word						
128	2	Input 5 Register, low word						
129	2	ut 6 Register, high word						
130	2	Input 6 Register, low word						
131	2	Input 7 Register, high word						
132	2	Input 7 Register, low word						
133	2	Input 8 Register, high word						
134	2	Input 8 Register, low word						
135	2	Input 9 Register, high word						
136	2	Input 9 Register, low word						
137	2	Input 10 Register, high word						
138	2	Input 10 Register, low word						
139-143	5	Date Stamp of Input 1, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
144-148	5	Date Stamp of Input 2, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
149-153	5	ate Stamp of Input 3, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
154-158	5	Date Stamp of Input 4, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
159-163	5	Date Stamp of Input 5, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
164-168	5	Date Stamp of Input 6, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
169-173	5	Date Stamp of Input 7, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
174-178	5	Date Stamp of Input 8, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
179-183	5	Date Stamp of Input 9, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
184-188	5	Date Stamp of Input 10, YEAR, MONTH, DAY, HOUR, MINUTE respectively						
189	1	Assign each input sample type. 0 = analog; 1 = pulse. Input 1;correspond to Bit0, input 2;correspond to bit1 and so on.						
190	2	Analog Input1 original data						
191	2	Analog Input2 original data						
192	2	Analog Input3 original data						
193	2	Analog Input4 original data						
194	2	Analog Input5 original data						
195	2	Analog Input6 original data						
196	2	Analog Input7 original data						
197	2	Analog Input8 original data						
198	2	Analog Input9 original data						
199	2	Analog Input10 original data						
200	1	Range Setting for each input.						
201	1	200 Correspond to input1						
202	1	201 Correspond to input2, etc.						
203	1	0 = Raw Data						
204	1	1 = 10K Celsius						
205	1	2 = 10K Fahrenheit						

# 1.6.5 List of Registers in the T3-4AO (Continued)

Address	Bytes	Register and Description							
206	1	3 = 0 - 100%							
207	1	4 = ON/OFF							
208	1	= OFF/ON							
209	1	= Pulse Input, 7 = Lighting Control							
210	1	Filter Coefficient for input 1, 0 through 100, default is 20.							
211	1	Filter Coefficient for input 2, 0 through 100, default is 20.							
212	1	Filter Coefficient for input 3, 0 through 100, default is 20.							
213	1	Filter Coefficient for input 4, 0 through 100, default is 20.							
214	1	Filter Coefficient for input 5, 0 through 100, default is 20.							
215	1	Filter Coefficient for input 6, 0 through 100, default is 20.							
216	1	Filter Coefficient for input 7, 0 through 100, default is 20.							
217	1	Filter Coefficient for input 8, 0 through 100, default is 20.							
218	1	Filter Coefficient for input 9, 0 through 100, default is 20.							
219	1	Filter Coefficient for input 10, 0 through 100, default is 20.							
220	1	Timer for Input 1, how long time the lighting control take over the outputs							
221	1	Timer for Input 2, how long time the lighting control take over the outputs							
222	1	Timer for Input 3, how long time the lighting control take over the outputs							
223	1	Timer for Input 4, how long time the lighting control take over the outputs							
224	1	Timer for Input 5, how long time the lighting control take over the outputs							
225	1	ner for Input 6, how long time the lighting control take over the outputs							
226	1	er for Input 7, how long time the lighting control take over the outputs							
227	1	Timer for Input 8, how long time the lighting control take over the outputs							
228	1	Timer for Input 9, how long time the lighting control take over the outputs							
229	1	Timer for Input 10, how long time the lighting control take over the outputs							
230	1	Input 1 Timer Left, how much time left for the lighting control							
231	1	Input 2 Timer Left, how much time left for the lighting control							
232	1	Input 3 Timer Left, how much time left for the lighting control							
233	1	Input 4 Timer Left, how much time left for the lighting control							
234	1	Input 5 Timer Left, how much time left for the lighting control							
235	1	Input 6 Timer Left, how much time left for the lighting control							
236	1	Input 7 Timer Left, how much time left for the lighting control							
237	1	Input 8 Timer Left, how much time left for the lighting control							
238	1	Input 9 Timer Left, how much time left for the lighting control							
239	1	Input 10 Timer Left, how much time left for the lighting control							
240	2	Light Control Disable/Enable, each bit correspond to one output, output1 correspond to least significant bit, 0 = disable, 1 = enable							
241	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
242	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
243	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
244	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
245	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
246	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
247	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							
248	1	Select which input as lighting control trigger, 0 = disable lighting control, 1= input1, 2=input2							

List of Registers for the T3-PT10									
Address	s Bytes Register and Description								
0~3		Serial number							
4		Firmware version number							
5		software version number							
6		nodbus service address							
7		product model							
8		ardware model							
9		audrate							
10		spare							
11		spare							
12		hardware Calibration flag write 2 to this register to hardware calibration.							
13		set modbus float int 0= float 1 = int. when set INT, 250 = 25.0C. When set float, show temperature directly 25.0000C							
18		Resolution (Resol:XXX.XXX): - Set the period for serial transmission							
18~21		spare							
22		Heartbeat register: It will increase every min from 0 to 255 and cycle the roution							
23~99		spare							
100~101	4	When set INT, 100 will show 0 and 101 show the temperature for channel 1, 250= 25.0C when set flaot,100 and 101 show 25.0000C							
102~103	4	When set INT, 102 will show 0 and 103 show the temperature for channel 2, 250= 25.0C when set float, 102 and 103 together show 25.0000C							
104~105	4	When set INT, 104 will show 0 and 105 show the temperature for channel 3, 250= 25.0C when set float, 104 and 105 together show 25.0000C							
106~107	4	When set INT, 106 will show 0 and 107 show the temperature for channel 4, 250= 25.0C when set float, 106 and 107 together show 25.0000C							
108~109	4	When set INT, 108 will show 0 and 109 show the temperature for channel 5, 250= 25.0C when set float, 108 and 109 together show 25.0000C							
110~111	4	When set INT, 110 will show 0 and 111 show the temperature for channel 6, 250= 25.0C when set float, 110 and 111 together show 25.0000C							
112~113	4	When set INT, 112 will show 0 and 113 show the temperature for channel 7, 250= 25.0C when set float, 112 and 113 together show 25.0000C							
114~115	4	When set INT, 114 will show 0 and 115 show the temperature for channel 8, 250= 25.0C when set float, 114 and 115 together show 25.0000C							
116~117	4	When set INT, 116 will show 0 and 117 show the temperature for channel 9, 250= 25.0C when set float, 116 and 117 together show 25.0000C							
118~119	4	When set INT, 118 will show 0 and 119 show the temperature for channel 10, 250= 25.0C when set float, 118 and 119 together show 25.0000C							
120~129		spare							
130~136	6	real time .second, minute, hour, day, week, month, year							
140~159	20	Temperature offset. 140~141 for channel 1 offset 142~143 for channel2 offset ect when set float , 140 and 141 default is 100.000. when set int,140 and 141 default is 100 .							
160~167	8	four point calibration raw AD data. (long type)							
168~173	6	channel 1 RTD parameter.							
174~179	6	channel 2 RTD parameter.							
180~185	6	channel 3 RTD parameter.							
186~191	6	channel 4 RTD parameter.							
192~197	6	channel 5 RTD parameter.							
198~203	6	channel 6 RTD parameter.							
204~209	6	channel 7 RTD parameter.							
210~215	6	channel 8 RTD parameter.							

	List of Registers for the T3-PT10 Continued					
Address	Bytes	Register and Description				
216~221	6	channel 9 RTD parameter.				
222~227	6	channel 10 RTD parameter.				
228	1	range for channel1 0 =C 1=F 2 = ohm.				
229	1	range for channel2 0 =C 1=F 2 = ohm.				
230	1	range for channel3 0 =C 1=F 2 = ohm.				
231	1	range for channel4 0 =C 1=F 2 = ohm.				
232	1	range for channel5 0 =C 1=F 2 = ohm.				
233	1	range for channel6 0 =C 1=F 2 = ohm.				
234	1	range for channel7 0 =C 1=F 2 = ohm.				
235	1	range for channel8 0 =C 1=F 2 = ohm.				
236	1	range for channel9 0 =C 1=F 2 = ohm.				
237	1	range for channel10 0 =C 1=F 2 = ohm.				
238	1	filter for channel 1 default = 20				
239	1	filter for channel 2 default = 20				
240	1	filter for channel 3 default = 20				
241	1	filter for channel 4 default = 20				
242	1	filter for channel 5 default = 20				
243	1	filter for channel 6 default = 20				
244	1	filter for channel 7 default = 20				
245	1	filter for channel 8 default = 20				
246	1	filter for channel 9 default = 20				
247	1	filter for channel 10 default = 20				

# List of Registers for the T3-6CT

Address	Bytes	Register and Description						
0 to 3	4	Serial Number, 4 byte value						
4	1	EEPROM Hardware Version Number						
5	1	irmware Version Number						
6	1	DRESS. Modbus Device Address						
7	1	Product Model						
8	1	Hardware Revision						
9	1	PIC Version Number						
10-12		Reserved						
13	1	Calibration Register-Used to calibrate the outputs						
14		Reserved						
15	1	Baudrate Setting: 0 = 9600bps, 1 = 19200bps						
16		Reserved						
17	1	Deadmaster time unit:minute defult:10						
18	1	Set the realy status when deadmaster time is finish.0:nochange. 1:on .2:off.						
22	1	Heartbeat register: It will increase every min from 0 to 255 and cycle the roution						
100	2	put 1 Register						
101	2	tput 2 Register						
102	2	utput 3 Register						
103	2	put 4 Register						
104	2	Output 5 Register						
105	2	Reserved						
106	2	Reserved						
107	2	Reserved						
108	2	CT Input 1 Register						
109	2	CT Input 2 Register						
110	2	CT Input 3 Register						
111	2	CT Input 4 Register						
112	2	CT Input 5 Register						
113	2	CT Input 6 Register						
114	2	Analog Input 1 Register						
115	2	Analog Input 2 Register						
116	2	Analog Input 3 Register						
117	2	Analog Input 4 Register						
118	2	Analog Input 5 Register						
119	2	Analog Input 6 Register						
120	2	Analog Input 7 Register						
121	2	Analog Input 8 Register						
122	2	Analog Input 9 Register						
123	1							
124	1	טאונהו שמות ו הכשוטנו						

# List of Registers for the T3-6CT Continued

Address	Bytes	Register and Description					
125	1	Switch Bank 2 Register					
126	1	Range Setting for each input					
127	1	26 correspond to input1					
128	1	7 correspond to input2, etc.					
129	1	0 = raw data,					
130	1						
131	1	1 = 10K Celsius,					
132	1						
133	1						
134	1	2 = 10K Fahrenheit					
135	1						
136	1						
137	1	= 0-100%					
138	1						
139	1	4 = ON/OFF					
140	1						
141	1	5 = OFF/ON					
142	1	Filter coefficient for input 1,0 through 100,default is 20.					
143	1	ilter coefficient for input 2,0 through 100,default is 20.					
144	1	Iter coefficient for input 3,0 through 100,default is 20.					
145	1	Filter coefficient for input 4,0 through 100,default is 20.					
146	1	Filter coefficient for input 5,0 through 100,default is 20.					
147	1	Filter coefficient for input 6,0 through 100,default is 20.					
148	1	Filter coefficient for input 7,0 through 100,default is 20.					
149	1	Filter coefficient for input 8,0 through 100,default is 20.					
150	1	Filter coefficient for input 9,0 through 100,default is 20.					
151	1	Filter coefficient for input 10,0 through 100,default is 20.					
152	1	Filter coefficient for input 11,0 through 100,default is 20.					
153	1	Filter coefficient for input 12,0 through 100,default is 20.					
154	1	Filter coefficient for input 13,0 through 100,default is 20.					
155	1	Filter coefficient for input 14,0 through 100,default is 20.					
156	1	Filter coefficient for input 15,0 through 100,default is 20.					
157	1	Filter coefficient for input 16,0 through 100,default is 20.					

For example, if we would like to read the input 2 register at module node address #1,

Slave Address	Function	Starting Address Hi	Starting Address Lo	No. of Points Hi	No. of Points Lo	CRC Hi Byte	CRC Hi Byte
1	3	0	109	0	1	xx	xx

Or we read 8 values after input 2 in module 1,

Slave Address	Function	Starting Address Hi	Starting Address Lo	No. of Points Hi	No. of Points Lo	CRC Hi Byte	CRC Hi Byte
1	3	0	109	0	8	xx	xx

Or we write 600 to output 4 in module 1,

Slave Address	Function	Starting Address Hi	Starting Address Lo	No. of Points Hi	No. of Points Lo	CRC Hi Byte	CRC Hi Byte
1	6	0	103	0	600	XX	xx

More details can be found in Modbus Secial Communication Section below.

# 1.6.7 Note About Registers When Updating the Firmware

There are two registers that will tell the CPU information about the model and hardware of the T3-Module.

NOTE: after updating the firmware you MUST setup these registers first or the module may not function properly.

Product Model is Register Address 7. The model number is already configured and it's a fixed number when it leaves the factory. There is no need for the customer to do anything.

The corresponding values are as follows:

• T3-4AO	= 28
• T3-8AIAO	= 21
• T3-8I13O	= 20
• T3-32AI	= 22
• T3-6CT	= 29
• T3-PT10	= 26

Hardware revision is register address 8. The hardware revision can be found by removing the front cover of the module. It is written in white silkscreen on the edge of the board.

# 1.7 Lighting Control with the T3-8I-13O Module

It is possible to use the T3-Module as a lighting control module. The logic is embedded directly in the T3-Module to make light switching response faster and reduce the polling required for lighting applications. The idea is that each input can be configured as a lighting switch input. Any or all of the inputs can be configured this way. Each input corresponds to one lighting zone.

Next, any or all of the outputs can be assigned to any of the zones. Finally, each zone has a timer which allows the operator to set how long the zone will go to "occupied mode".

An additional set of timers show how much time is left for a particular override event, these are read/write registers so that the Master can initiate events and override events already under way. Finally, there is an auto/manual bit for each output to override the local T3 logic, for example during commissioning or special events.

1. • The "Range" for each input is configured in registers 183 thru 190,

set any input to act as a lighting switch by setting the range to 7.

- Each input corresponds to one zone,
- Short circuit the input to GND and this will trigger an event
- If the zone was previously on, it will flip to off and vice versa.
- 2. Each Zone has an 'override time' setting which sets how long the lights will be triggered on for a particular hit of the switch.
  - The values are in minutes, they are read/write and are stored in registers 199 thru 206,
  - 199 is the time for zone 1 which is controlled by input1
  - 200 for zone2 and so on..
- 3 Each zone has a 'time left' register which shows the remaining time left after a particular hit on the switch.
  - These are read/write values in 'minutes' and are stored in registers 207 thru 214
  - Each time there is a hit on a particular hit on a light switch, the 'time left' register will be filled in with this 'over ride time' setting.
  - For example, a hit on switch 1 will trigger a copy of register 199 to register 207.
  - Then Register 207 will start counting down.
- 4 Each output has an auto/manual bit so that the lighting control logic (and any other future logic embedded in the module) can be disabled.
  - Register 215 , auto/manual register, 2 byte length.
  - 0 = manual (lighting control disabled),
  - 1 = auto (lighting control enabled).
  - Each bit corresponds to one output with output 1 starting at the least significant bit
  - Output 13 corresponds to the 13th bit.
- 5 Assign Outputs to Zones in registers 216 thru 228
  - 13 outputs, one register for each output which assigns that particular output to a particular zone.
  - Since there are 8 zones, the these registers will accept a value from 1 to 8,
    - 0 = n/a,
    - 1 = means this output will be linked to zone1 (and controlled by input1).
    - 2 = means this output will be linked to zone2 (and controlled by input2).
    - ETC

# 1.8 Installation

# 1.8.1 Terminal Block Connections (T3-8IO)



# 1.8.3 Terminal Block Connections (T3-8-13



1.8.5 Terminal Block Connections (T3-6CT)



# 1.8.2 Terminal Block Connections (T3-32I)



# 1.8.4 Terminal Block Connections (T3-4AO)



# 1.8.6 Terminal Block Connections (T3-PT10)



# **1.9 Typical Sensor Inputs**



# 2.0 Network Diagram



A Tie GNDs to earthground at each cabinet.

# 1.9.6 Mounting

- External wiring is connected to a terminal block on the circuit board
- The enclosure is comprised of a base section and a cover
- The base section can be mounted directly on a wall or on a wall box
- Length of cables : No practical limitation on cable length



# 1.9.7 T3-4AO Jumper Settings



# 2 Modbus Serial Communications

# 2.1 Overview

Modbus protocol is a widely used and well-documented communication method. It provides simple and effective means of programming our various products.

A typical Modbus packet looks like this:

- Byte1 Modbus ID, the destination address for a particular message
- Byte2 Function
- Byte3 Starting address of the particular storage registers) to be read or written, hi byte,
- Byte4 Starting address low byte
- Byte5 No. of registers to read/write (hi byte)
- Byte7 CRC hi byte
- Byte8 CRC low byte

During normal operation, the slave will immediately send a response to the master request.



[Notice]: Most errors during message transfer are timeout errors. This is because bytes being distorted or missing will not trigger a response, resulting in a timeout error.

Software tools can be found at: http://www.modbustools.com/modbus\_poll.asp If your application can read & write bytes to a separate PC running the 'Modbus Slave' application, you will be able to read & write bytes to theTstat5. Note: When using the Modbus Poll software, addressing should be set to "Protocol Addresses (Base 0)" under the "Display" menu.

# 2.2 Modbus Examples

# 2.2.1 READ Command (0x03)

This function is used to read the contents of multiple memory registers. The master to the Modbus must specify, the Modbus ID, it's starting register and quantity of register desired. By convention if a data were to contain 2 byte, we would first send the Hi byte and then the Lo byte. You can change the Modbus ID whatever you want by writing register 6.

The master to the Modbus network will issue a read command:

- Modbus ID=11
- Read 6 bytes of data
- Starting at register number 107 (6Bh)

Byte #	Field Name (Hex)	Data	Description
Byte1	Slave Address	11	Tstat with ID11 will be read
Byte2	Function	03	Read operation
Byte3	Starting Address Hi	00	
Byte4	Starting Address Lo	6B	Reading starting from register #6B
Byte5	No. of Register to read Hi	00	
Byte6	No. of Register to read Lo	03	Read a total of 3 registers
Byte7	Error Check ( CRC) HI byte	XX	The CRC is calculated using the CRC
Byte8	Error Check ( CRC) LO byte	XX	Routine described below

The slave device with ID=11 will answer the master within a few milliseconds with the following response.

Byte #	Field Name (Hex)	Data
Byte1	Slave Address	11
Byte2	Function	03
Byte3	Byte Count	06
Byte4	Data1 Hi	02
Byte5	Data1 Lo	2B
Byte6	Data2 Hi	00
Byte7	Data2 Lo	00
Byte8	Data3 Hi	00
Byte9	Data3 Lo	64
Byte10	Error Check (CRC) HI byte	XX
Byte11	Error Check ( CRC) LO byte	XX

Description
 Slave with ID11 is responding
 We're responding to a read command
 6 bytes are coming
 Byte1 of the data
 Byte2 of the data
 Byte3 of the data
 Byte4 of the data
 Byte5 of the data
 Byte6 of the data
 The CRC is calculated using the CRC
 Routine described below

Example of the Read Command:

The Master sends the Read querie:

Slave Address	Function	Starting Address Hi	Starting Address Lo	No. of Points Hi	No. of Points Lo	CRC Hi Byte	CRC Lo Byte
11	3	0	(6Bh) 107	0	3	хх	xx

The device node sends back the following response:

Slave Address	Function	Byte Count	Data1 Hi	Data1 Lo	Data2 Hi	Data2 Lo
11	3	6	(02h) 2	(2Bh) 43	(00h) 0	(00h) 0

Data3 Hi	Data3 Lo	CRC Hi Byte	CRC Lo Byte
(00h) 0	(64h) 100	хх	хх

# 2.2.2 WRITE command (0x06)

This function is used to write to a single memory register. The master of the Modbus must specify the Modbus ID, its register address to be written and the data desired.

The master to the Modbus network will issue a write command:

- Modbus ID=11
- Write to address 11
- Enter data 3 (03h)

Byte #	Field Name (Hex)	Data	Description
Byte1	Slave Address	11	Destination address
Byte2	Function	06	This is a write command
Byte3	Register Address Hi	00	Address which will be written to, hi byte
Byte4	Register Address Lo	01	Address which will be written to, low byte
Byte5	Data Hi	00	Data that we are writing, hi byte
Byte6	Data Lo	03	Data we are writing, low byte
Byte7	Error Check ( CRC) HI byte	XX	The CRC is calculated using the CRC
Byte8	Error Check (CRC) LO byte	XX	Routine described below

The slave device with ID=11 will answer the master within a few milliseconds with the following response.

Byte #	Field Name (Hex)	Data	Description
Byte1	Slave Address	11	Destination address
Byte2	Function	06	This is a write command
Byte3	Register Address Hi	00	Address which will be written to, hi byte
Byte4	Register Address Lo	01	Address which will be written to, low byte
Byte5	Data Hi	00	Data that we are writing, hi byte
Byte6	Data Lo	03	Data we are writing, low byte
Byte7	Error Check ( CRC) HI byte	XX	The CRC is calculated using the CRC
Byte8	Error Check (CRC) LO byte	XX	Routine described below

[Notice]: In this case the Slave device just sends back the message to let the Master know the query has been prop erly received.

Example of the Write Command

The Master sends the Write Query:

Slave Address	Function	Starting Address Hi	Starting Address Lo	Data Hi	Data Lo	CRC Hi Byte	CRC Lo Byte
11	6	0	(01h) 1	0	3	хх	хх

The device node sends back the following response:

Slave Address	Function	Starting Address Hi	Starting Address Lo	Data Hi	Data Lo	CRC Hi Byte	CRC Lo Byte
11	6	0	(01h) 1	0	3	хх	хх

#### 2.2.3 MULTIPLE-WRITE Command (0x10)

This function is used to write to multiple memory registers. The master of the Modbus must specify the Modbus ID, its starting address register, the amount of register desired and the data. NOTE: This is used for firmware update only. It is not used to write device registers.

The master to the Modbus network will issue a multiple-write command:

- Modbus ID=11
- Write to address 291 (123h)
- Number of Registers 3
  Data 1 = 10 (000Ah)
- Data 2 = 11(000Bh) Data 3 = 12 (000Ch)

Byte # Byte1 Byte2 Byte3	Field Name (Hex) Slave Address Function Register Start Address H	i	<b>Data</b> 11 10 01 23	<b>Description</b> Destination address ID 11 This is a multiple write command This is the address we are currently writing to in the code space of the device In this case we want to write to register address 0x0123
Byte5 Byte6 Byte7	Quantity of Registers to v Quantity of Registers to v Byte Count	vrite Hi vrite LOW	20 00 10 20	We will be writing a variable amount of bytes at a time in this case we want to write to 10H or 16 registers If byte count is the same as number of Registers, dealing with 8 bits. If byte count is the same as number of Registers, dealing with 16 bits.
<b>Byte #</b> Byte8 Byte9 Byte10	<b>8 bits</b> Data 1 Data 2 Data 3	<b>Byte #</b> Byte8 Byte9 Byte10		<b>16 bits</b> Data1 Hi Data1 Lo Data2 Hi

HI
LO

[Notice]: Byte 7 is used as a byte count. Thus if the byte count is the same as the number of registers to write then we know we are dealing with 1 byte registers. Similarly, if the byte count is double the number of registers, we are dealing with 2 byte registers.

The slave device with ID=11 will answer the master within a few milliseconds with the following response.

Byte #	Field Name (Hex)	Data	Description
Byte1	Slave Address	11	Destination node ID
Byte2	Function	10	This is a multiple write command
Byte3	Register Start Address Hi	00	Starting address we are writing to, hi byte
Byte4	Register Start Address Lo	01	Start address low byte
Byte5	Quantity of Registers Hi	00	Number of registers to be written to, hi byte
Byte6	Quantity of Registers Lo	0A	Number of registers, low byte
Byte7	Error Check ( CRC) HI byte	XX	The CRC is calculated using the CRC
Byte8	Error Check (CRC) LO byte	XX	Routine described previously

Example of the Multiple-Write Command

The Master sends the Multiple-Write querie:

Slave Address	Function	Starting Address Hi	Starting Address Lo	Quantity. of Regs Hi	Quantity. of Regs Lo	Byte Count
11	(10h) 16	(01h) 1	(23h) 35	0	3	6

Data 1 Hi	Data 1 Lo	Data 2 Hi	Data 2 Lo	Data 3 Hi	Data 3 Lo	CRC Hi Byte	CRC Lo Byte
(00h) 00	(0Ah) 10	(00h) 00	(0Bh) 12	(00h) 00	(0Ch) 13	xx	xx

Slave Address	Function	Starting Address Hi	Starting Address Lo	Quantity. of Regs Hi	Quantity. of Regs Lo	CRC Hi Byte	CRC Lo Byte
11	10	(01h) 1	(23h) 35	0	3	xx	xx

# 2.3 CRC Error Correcting Details

The following is a collection of code snippets to get your application started:

# static unsigned char auchCRCHi[] = {

0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00,

};

/\* Table of CRC values for low-order byte \*/

# static unsigned char auchCRCLo[] = {

0x00, 0xC0, 0xC1, 0x01, 0xC3, 0x03, 0x02, 0xC2, 0xC6, 0x06, 0x07, 0xC7, 0x05, 0xC5, 0xC4, 0x04, 0xCC, 0x0C, 0x0D, 0xCD, 0x0F, 0xCF, 0xCE, 0x0E, 0x0A, 0xCA, 0xCB, 0x0B, 0xC9, 0x09, 0x08, 0xC8, 0xD8, 0x18, 0x19, 0xD9, 0x1B, 0xDB, 0xDA, 0x1A, 0x1E, 0xDE, 0xDF, 0x1F, 0xDD, 0x1D, 0x1C, 0xDC, 0x14, 0xD4, 0xD5, 0x15, 0xD7, 0x17, 0x16, 0xD6, 0xD2, 0x12, 0x13, 0xD3, 0x11, 0xD1, 0xD0, 0x10, 0xF0, 0x30, 0x31, 0xF1, 0x33, 0xF3, 0xF2, 0x32, 0x36, 0xF6, 0xF7, 0x37, 0xF5, 0x35, 0x34, 0xF4, 0x3C, 0xFC, 0xFD, 0x3D, 0xFF, 0x3F, 0x3E, 0xFE, 0xFA, 0x3A, 0x3B, 0xFB, 0x39, 0xF9, 0xF8, 0x38, 0x28, 0xE8, 0xE9, 0x29, 0xEB, 0x2B, 0x2A, 0xEA, 0xEE, 0x22, 0xE2, 0xE7, 0xE7, 0xE7, 0xE7, 0x65, 0x65, 0x64, 0xA4, 0x60, 0x61, 0xA1, 0x63, 0xA3, 0xA2, 0x66, 0xA6, 0xA7, 0x67, 0xA5, 0x65, 0xA4, 0xA4, 0x6C, 0xAC, 0xAD, 0x6D, 0xAF, 0x6F, 0x7B, 0x7B, 0x7A, 0xBA, 0x6B, 0x7E, 0x7F, 0xBF, 0x77, 0xB7, 0xB5, 0x74, 0x75, 0xB5, 0x73, 0xF1, 0x73, 0xF1, 0x74, 0x75, 0x85, 0x64, 0xA4, 0x66, 0xA7, 0x67, 0xA5, 0x65, 0x64, 0xA4, 0x6C, 0xAC, 0xAD, 0x6D, 0xAF, 0x6F, 0x7F, 0xB7, 0xB6, 0x72, 0xE7, 0xE7, 0xB4, 0x74, 0x75, 0xB5, 0x77, 0xB7, 0xB7, 0xB6, 0x72, 0xB4, 0x73, 0xB1, 0x71, 0x70, 0xB0, 0x50, 0x90, 0x91, 0x51, 0x93, 0x53, 0x52, 0x92, 0x96, 0x56, 0x57, 0x97, 0x55, 0x95, 0x94, 0x54, 0x9C, 0x5C, 0x5D, 0x9D, 0x5F, 0x9F, 0x9E, 0x5E, 0x5A, 0x9A, 0x4B, 0x6B, 0x4B, 0x69, 0xA8, 0x48, 0x49, 0x80, 0x40, 0x44, 0x44, 0x4E, 0x8E, 0x4F, 0x8D, 0x4D, 0x4C, 0x8C, 0x44, 0x84, 0x85, 0x45, 0x87, 0x47, 0x46, 0x86, 0x82, 0x42, 0x43, 0x83, 0x41, 0x81, 0x80, 0x40

};

For example: to calculate the crc of the data in the message stored in memory location \*puchMsgunsigned short CRC16 (unsigned char \*puchMsg, unsigned char usDataLen {

```
unsigned char uchCRCHi = 0xFF ; /* high byte of CRC initialized */
unsigned char uchCRCLo = 0xFF ; /* low byte of CRC initialized */
unsigned uIndex ; /* will index into CRC lookup table */
while (usDataLen--) /* pass through message buffer */
```

```
uIndex = uchCRCHi ^ *puchMsg++ ; /* calculate the CRC */
uchCRCHi = uchCRCLo ^ auchCRCHi[uIndex] ;
uchCRCLo = auchCRCLo[uIndex] ;
}
return (uchCRCHi << 8 | uchCRCLo) ;</pre>
```

```
}
```

{

# 2.4 Modbus Poll Software

Modbus Poll is a simple modbus communications tool developed by Witte Communications http://www.modbustools. com/modbus\_poll.asp that can be used to read and write registers of modbus devices. The following is a brief set of instructions for communicating with a device.

The first time Modbus Poll is used, it should be set to base 0 addressing. This is done by selecting "Protocol Addressing (Base 0) " from the Display menu:

File Cor	nnection	Setup	Functions	Display	View	Window	Help
		3 X	日 [思]	✓ Signe	d		
Mbp	oll 1			Unsig Hex	ned		
Tx =	1154:	Err =	1021:	Binary	1		
No co	nnect	ion		Long			
00101	=	240	00124	Long	Inverse	5	
00102	=	1000	00125	Float			
00103	=	0	00126	Float	Inverse	e	
00104	=	0	00127	Doubl	0		
00105	=	0	00128	Doubl	o Invoi	100	
00106	=	1	00129	Dodde	e myei	20	
00107	=	з	00130	PLC A	ddress	es (Base 1	)
00108	=	19	00131	V Proto	col Add	resses (Ba	ise 0)
00109	=	500	00132		1.5		
00110	=	500	00133	Comm	nunicati	on	

The Setup menu:

File Connection	Setup	Functions	Display	View	Window Help	
	Poll	Poll Definition F2		05 06 15 16 22		
Mbpoll1 Tx = 1154:	Log	iuns iin		55:	F = 03: SR	
No connect	i Logi		510	10		
00102 =	1 Use	as Default	F12	0		
00103 =				20		

At this point, the connection to the device needs to be established. Select "Connect..." from the Connection menu:



Unless the device has specifically been setup for 9600 baud, the default connections settings should be as follows:

Port 1	RTU C ASCII	OK
19200 Baud 💌 3 Data bits 💌	Response timeout	Cancel
None Parity 💌 I Stop Bit 💌	Flow control	
Remote Server	Port	

After the connection is established, it is necessary to setup the poll definitions. This is done by selecting "Poll Definition..." from the Setup menu:



Within the Poll Definitions dialog window, there are several parameters that need to be set.

- Slave ID is the modbus address of the device being read or written. (255 is the generic address to which all devices will respond.)
  - Function should be set as 03 HOLDING REGISTER.
  - Address is the starting address of the registers to be read.
  - Length is the number of registers to be read.
  - Scan Rate is the frequency with which the device will be polled.

Poll Definiti	on		×
Slave ID:	255		OK
Function:	03 HOLD	ING REGISTER 💌	Cancel
Address:	101		
Length:	40		Apply
Scan Rate:	1000	ms	
🔽 Auto Re	ad Enable		Read Once

Once the Poll Definitions have been setup and applied, the main window will show a list of each register address and its corresponding value.

_ [0]	and the second			Mapol	dbus Poll	M
	Help	day time W	Functions Dep	Setup	Connection	-
	22 23 101 8 1	JL 05 06	<b>日</b>  夏白	X	6	
					bpo#1	1 N
	5R = 1000mm	= 2551 F	1302; ID	Err -	14411	TX 4
		10	00124 =	205	11 ×	5010
		0	00125 =	0	12	001
		20	C0125 =	0	12 =	001
		2	00117 -	53	14 -	001
		1	00128 =	0	15 =	001
		C	00129 =	0	16 =	001
		0	00100 -	0	- 11	001
		50	CO131 =	31	8 =	001
		15	00132 =	500	19 =	001
		o	00100 -	500	10 -	001
		0	G0134 =	0	11 =	001
		20	00135 =	100	12	001
		19	00135 =	0	13 =	001
		4	00137 -	2	14 =	001
		0	00118 =	5	15 =	001
		0	C0139 =	0	16 =	001
		0	00140 -	0	17 -	001
				1	· 8	001
				10	19 =	001
				10	- 01	DOI
				0	1	001
				. 3	2 .	001
				10	- 2	001
N.M		a value.	, double click on	. For Ed	o, press F1	or Hei

In order to write a value to a specific register, select "06 Write Single Register..." from the Functions menu:

File Connection Setup	Functions Display View Window	Help
D 📽 🖬 🚭 🗙	Read Once F6	22
The loss of the lo	05: Write Single Coil F7	
Mbpoll1	06: Write Single Register. 📐 F8	
Tx = 1162: Err =	15: Write Coils 15 F9	SR
Timeout error	16: Write Registers F10	
00101 = 240	22: Mask Write Register	
00102 = 1000	23: Read/Write Registers	
00103 = 0		-
00104 = 0	Test Center	

Slave ID is the modbus address of the device. Address is the address of the register that will be written. Value is the value being written.

Write Single	Register	×
Slave ID:	255	Send
Address:	0	Cancel
Value:		
Use funct © 06: W © 16: W	ion rite single registe rite multiple regis	er ters

# **3** Instructions for Updating Devices with Temco ISP

For TEMCO devices that utilize the Temco ISP, the flash update must be done using the provided NWT3000. To perform a firmware update, follow these instructions:

1.) Download and install the NWT3000 software: http://www.temcocontrols.com/ftp/software/9TstatSoftware.zip

2.) Connect the device to the serial port of your computer using the RS232-485 converter included in the package.

3.) Power up the device.

4.) Open the NWT3000 software and select Update Firmware from the Tool menu:



5.) The software will now open the Update Firmware window and will scan for available devices.

nd Found 1 N	xtesi						Cepy To Al
Secial# ID 4156	Deutrote      19200	landinaria Risk Dannos 9 Totatos	Soltware res 26.2	nexfile		Ensble	Seve Settinge Palse
		3.m	rlehA		Select Free File	 a	
Santrd Found	I L Nodes (						

- 6.) For each device that is found, you can specify the hex file to be used for the update. Do this by clicking in the Hex File column of the row you wish to specify. Alternatively you can click Select Hex File and then "Copy to All" if all devices are to receive the same file. You can also choose to save the current settings or to load the default settings by selecting True or False from the Save Settings column.
- 7.) At this point simply click Flash All and the software will update each device one by one.

# 3.1 Protocol for Developers Wanting to Update Devices with Temco ISP

All devices programmed with Temco ISP are capable of being updated over the RS485 network. The master on the network sends a command to a particular device, which forces it to go into a 'flash update mode'. The device first resets itself and then jumps to the 'In System Programming' (ISP) code section. Note that all non-volatile parameters should be read and saved prior to this for safe keeping.

NOTE: Multiple-Write Command of the Modbus protocol is used.

# 3.1.1 Protocol

In order for the front end to communicate with the ISP flash, a series of registers have been defined, which are used as control registers for the Update functions. Reading and writing to these registers will allow the Front end to monitor the status of the update process. They are stored in the non-volatile memory space to keep track of the steps attempted and completed. Below is a description of these control status registers.

Register	Register address	Description
EEPROM_VERSION_NUMBER	4	Software Version
EEP_ADDRESS	6	ID number of the device
EEP_UPDATE_STATUS	16	Update Register state

Table 1.	Flash	Update	Function	Registers
	1 10011	opaalo	i unouon	riogioloro

It is important to note 'EEP\_UPDATE\_STATUS' which is located at register address 16. Writing to this register will cause the device to either reset itself, erase its flash or start programming depending on the action being taken. Below is a description of the values and explanation of the EEP\_UPDATE\_STATUS register.

Function	Value	Description of EEP_Update_Status
Update initialize	7Fh	Tell the Tstat to reset and jump into the ISP to be in update mode
Update ready		Tstat is in the ISP and ready to update
Erase flash	3Fh	Tell the Tstat to erase Flash Memory
Erase done		Erase Flash Memory done
Start Programming	1Fh	Start Programming - In upload state
Normal State	01h	Update is complete, tstat reboots with new flash image

Table 2. EEP\_UPDATE\_STATUS register value description

- For the device to jump into update mode, a write command of value 7Fh must be sent to the EEP\_UPDATE\_STA TUS. The device will then reset itself and run in ISP mode.
- **Note:** The device will not send any response in this step. To verify the T3-Module is in ISP mode, the same write command must be sent again (write 7Fh to register #16), at which point the T3-Module will respond with a regular modbus response. This is necessary for clearing the Interrupt vectors and making sure all RAM memory is cleared.
- All Modbus communication commands are followed by a response. This Flash Update Protocol makes use of that criteria and thus only sends a response once the action has been completed. Therefore the 'update initial ize' and 'erase flash' step require a longer timeout period than the 'programming' step. (250ms and 500ms respec tively)
- Sending a write command of value 3Fh to EEP\_UPDATE\_STATUS will force the device to erase its entire flash memory. Once the response is received, the device is ready to download the data of the new firmware.
- Sending a write command of value 1Fh to EEP\_UPDATE\_STATUS will let the device know it is about to receive new firmware. The device is now ready to accept the new hex file and will maintain a running tally of the current programming location in the EEP\_UPDATE\_PTR.
- At this point, the data must be sent using the multiple-write command. Packets can be of size 1 data byte to a maximum of 128 data bytes.
- In the event of an interrupted flash update, the Master can poll the EEP\_UPDATE\_PTR and begin programming from this location.

# 3.1.2 Example of a Programming Routine

The ISP has been designed using polling vectors rather than Interrupt vectors in order to free up as many interrupts for the program itself. Given that polling is now used, communications are more susceptible to timing and response delay problems. Therefore, when sending a write function or multiple write function to the ISP device, a short timeout delay is required before receiving a response (≈20ms). If a response was not received during that period of time the FRONT END would need to resend the data once again. Below is a diagram representation of the Flash-Update Protocol.

Front End	Tstat
Update Initialize (7Fh) Command Write to Update Register Value 7Fh Command Write to Update Register Value 7Fh	<ul> <li>Device Reset</li> <li>Update Ready</li> <li>Ready Update Register Value         <ul> <li>(if value = 7Fh )                 jump to ISP</li> </ul> </li> </ul>
Erase Flash (3Fh) Response Received Command Write to Update Register value 3Fh	Send response to write query
	Erase Done
	Ready Update Register Value ( if value = 3Fh ) start to erasing Send response to write guery
Start Programming (1Fh) Response Received Command Write to Update Register Value 1Fh	
Programming Mode Multiple Write Response Received Flash Multiple Write Address Length Data End of File (01h) End of File found in Hex file Command	Store point to address in register Store version number in register Store Data Send response to write/multiple write query
Write to Update Register Value 01h	Programming Done End of File Received Store remaining data Reset pointer to addr and set update Reg to 01h Jump to firmware code (200h)

# 3.1.3 Example of a Programming Routine (Front End Side)

#### UPDATE INITIALIZE

- 1 Send Modbus Write Command to address Update\_Register value 7Fh
  - The device will reset itself. Make sure all volatile infomation be saved prior to this step
  - Device will not send a respond
- 2 Send Modbus Write Command to address Update\_Register value 7Fh again
  - A response will be received if the Device has properly reset itself and booted under ISP mode

#### ERASE FLASH

3

- Send Modbus Write Command to address Update\_Register value 3Fh
- A response will be received once the Device has properly Erase all Flash Memory
- This will step require a longer response timeout period (approx 500ms)

#### TART PROGRAMMING

- Send Modbus Write Command to address Update\_Register value 1Fh
  - A response will be received once the Device has properly set itself for programming mode

# PROGRAMMING MODE

- 5 Extracting data from Intel Hex file. A typical line would look like the following:
  - :10 0080 00 AF5F67F0 602703E0 322CFA92 007780C3 FD
- 6 Verify checksum  $10 \pm 00 \pm 08 \pm 00 \pm 45 \pm 0.024$ 
  - 10 + 00 +08 + 00 + AF + ... + C3 + FD = 900
  - If two last digits of the sum is zero, Hex file is correct
- 7 Send data using Modbus Multiple-Write Command Address 0080h Data length of 10h Data AF5F67F0 602703E0 322CFA92 007780C3
- 8 Repeat step 5 through 7 until end of Hex file is reached

IMPORTANT NOTE to ensure proper reset of the device, the value at address register 0000h of the Goal chip must remain as FF.

- Most (but not all) of Temco's Hex file will contain this line: :03 0000 00 020200 F9
- Data written to the Goal Flash register MUST be modified from 020200 to FF0200

#### END OF FILE

- 9 End of file found in Hex file :00 0000 01 FF
  - Bit 7 and 8 are 01
- 10 Send Modbus Write Command to address Update\_Register value 01h
  - This will cause the device to reset itself and boot in normal operation mode

# 3.1.4 To Resume a Previously Interrupted Programming Routine

The EEP\_UPDATE\_STATUS register keeps track of which step is being performed during the update protocol and the EEP\_UPDATE\_PTR keeps track of which register is currently being written to.

• If the device was in the Erase Flash mode, the EEP\_UPDATE\_STATUS register will read 3Fh. The Front End is then required to repeat this step and follow up from there.

• If the device was in the Programming mode, the EEP\_UPDATE\_STATUS register will read 1Fh. The Front Ends then needs to read the EEP\_ UPDATE\_PTR. In order to resume this step the Front End needs to re-write to this register again and then follow up from there.



The following diagram represents the update resume procedure.

#### **IMPORTANT:**

In order for the device to jump into the ISP mode, it has to reset itself. Upon reset, if the value at address register 0000h is FF, the device will jump to the ISP code section. This is a hardware criteria of the Goal Chip and an efficient way to jump to In System Programming mode while clearing all buffers. The front end must ensure that only value FF is to be written to address register 0000h. When reading the hex file, there will be a line like this: Data of the new firmare Modified data to be uploaded

;03 0000 00 020200 F9 ------ Needs to be changed to ------ ;03 0000 00 FF0200 FC (Intel Hex format described below):

# 3.1.5 Intel Hex File

All firmware files produced by our compilers are saved under the Intel Hex file format. This format of record can be broken down in its different fields as described below.

# 3.1.5.1 Example of an Intel Hex file

Take for instance a typical message such as the following:

- :ll aaaa tt D1D2D3D4 D5D6D7D8 D9D0D1D2 D3D4D5D6 ee
- :10 0080 00 AF5F67F0 602703E0 322CFA92 007780C3 61
- The first character (:) indicates the start of a record.
- The next two characters indicate the record length (10h).
- The next four characters give the load address (0080h).
- The next two characters indicate the record type. (00)
- Then we have our data

• The last two characters are a checksum (sum of all bytes + checksum = 00).

- Record types:
- 00 Data record
- 01 End of file record
- 02 Extended segment address record
- 03 Start segment address record
- 04 Extended linear address record
- 05 Start linear address record

# 3.1.6 Intel Hex File

In the case where the device is locked, there is still a possibility to reboot the device and upload a new firmware. This requires to physically link the jumpers of the Flash Update Jumper pins during restart:

- Power down the device
- Link the jumpers of the Flash Update Jumpers
- Power up the device

Doing the above steps will force the device to be in ISP mode so that new firmware can be loaded. In order to return to normal operation once the upload has been done the Jumper needs to be removed and power need to be recycled.

# 4 Getting Started and Installing T3 - Module

# 4.1 Getting Started:

When setting up your T3-Module please check and set the following settings, and read the following instructions in order to have the module function according to your specific needs.

- 1. Connect 2-Holed power adapter into the 2-Pin port marked "Power" on the T3-Module.
- 2. Plug the 24 V power cable into the wall.
- 3. Connect 3-Hole RS485 cableinto the 3-Pin port marked "RS485" on the T3-Module.
- 4. Connect the other end of the RS485 Cable into an empty Com Port in your computer.
- 5. If you have not installed Modbus Poll on your system, please do so now
  - i. Double click the file "ModbusPollSetup.exe"
  - ii. Accept the terms of the licence agreement and press "Next"
  - iii. Select your desired location to install the product and press "Next"
  - iv. Select the components you wish to install and press "Install"
  - v. Once the installation has completed press "Next"
  - vi. Press "Finish" to complete
- 6. On your computer open ModBus Poll
- 7. Before you start collecting data you must decide if you want to run your module in Base 1 or Base 0
  - Scroll over the "Display" tab and click to see the drop down menu
  - · Select "Base 1" or "Base 0" from the drop down menu

File Edit Connection Setup Functions	Dis	play View Window Help	
🗅 🗃 🖨 🎒 🗙 🛅 🗏 🚊 Г. 05 06 1	-	Signed	Alt+Shift+S
		Unsigned	Alt+Shift+U
		Hex	Alt+Shift+H
		Binary	Alt+Shift+B
		PLC Addresses (Base 1)	
	<ul> <li>Image: A start of the start of</li></ul>	Protocol Addresses (Base 0)	
		Error Counters	F11
		Communication	

• If you use "Base 0" the Registers will be set to those stated below

- If you use "Base 1" the Registers below will be modified by adding 40001
  - Ex. Base 0 Register 00186 = Base 1 Register 40187

ValueBase1 = ValueBase0 + 40001

- 8. Baud Rate controls the speed at which information is retrieved from the T3-Module. All T3-Modules can be set to either 19200 or 9600, 19200 being the faster speed.
  - To define the Baud Rate go to "Connections -> Connect" and define your Baud Rate.

입 Modbu	s Poll - Mbpoll1		Connection	X
File Edit	Connection Setup Functio	ns Display View Window Help		ок
D 🖨 🖬	Connect F3 Disconnect F4 Auto Connect + Quick Connect F5	15 16 22 23   101 😵 🎌	19200 Baud     Response timeout       19200 Baud     Image: Constraint of the second	Cancel

• If the Baud Rate is set to 19200 then "Double-Click" Register 15 and set the "Value" to "1"

9. Your Com Port must be set before your device can retrieve the information from the T3-Module.

- Different computers use different Com Ports, so you must first see which Com Port your device is using.
- 1. To do this Open Device manager and see which Com Port your T3-Module uses

File Edit Connection Setup Functions	Dis	play View Window Help	
🗅 🖨 🖨 🎒 🗙 🔚 🗒 🗒 🕮 🔂 1. 05 06 1	1	Signed	Alt+Shift+S
		Unsigned	Alt+S <mark>hift+U</mark>
		Hex	Alt+Shift+H
	1	Binary	Alt+Shift+B
		PLC Addresses (Base 1)	
	$\checkmark$	Protocol Addresses (Base 0)	
		Error Counters	F11
		Communication	

File Edit Connection Setup Functions	Dis	play View Window Help	
🗅 😅 🖬 🚭 🗙 🛅 🗮 🚊 💷 05 06 1	~	Signed	Alt+Shift+S
		Unsigned	Alt+Shift+U
		Hex	Alt+Shift+H
		Binary	Alt+Shift+B
		PLC Addresses (Base 1)	
	✓	Protocol Addresses (Base 0)	
		Error Counters	F11
		Communication	

# 2. Then set your Com Port within Mbpoll1

10. Press "OK" to connect to your T3-Module

•If you do not need to change these settings before beginning you may simply

press the (quick connect) icon.

# **3.2 Instructions**

# Input Registers Reference Table

#### Set Range Register

00183 = Input 1 00184 = Input 2 00185 = Input 3 00186 = Input 4 00187 = Input 5 00188 = Input 6 00189 = Input 7 00190 = Input 8

#### Pulse Counting Register

00118 – 00119 = Input 1 00120 – 00121 = Input 2 00122 – 00123 = Input 3 00124 – 00125 = Input 4 00126 – 00127 = Input 5 00128 – 00129 = Input 6 00130 – 00131 = Input 7 00132 – 00133 = Input 8

#### **Date Stamp Register**

00134 - 00138 = Input 1 00139 - 00143 = Input 2 00144 - 00148 = Input 3 00149 - 00153 = Input 4 00154 - 00158 = Input 5 00159 - 00163 = Input 6 00164 - 00168 = Input 7 00169 - 00173 = Input 8

To change Input Method please read and follow these steps:

We will use Input 1 for our example

- 1. Connect T3 Device to Serial Port
- 2. Open the program
- 3. Double-Click register "00183"
- 4. This will open a pop-up window titled "Write Single Register"

Write Single	e Register	
Slave ID:	254	Send
Address:	183	Cancel
Value:	3	
Use function © 06: Write © 16: Write Use functions Of the func	on te single register te multiple registe	:rs

- 5. Set "Value" to "6" for Pulse Counting
- 6. Click "Send" to Confirm
- 7. When asked "Request OK?" Click OK
- 8. Pulses will now be counted on Register 00118 and 00119
  - Register 00118 counts "1" for every "65535" pulses
  - Register 00119 counts single pulse

Ex. 70,000 pulses will be appear as 00118 = 1 00119 = 4465 Total Pulses = Value00118 x 65535 + Value00119 9. In order to save the data collected in Mbpoll1, the first step in using the T3-Module is to set the Date Stamp Register

CAUTION: Range Counter will reset immediately after writing date

- · Before you begin counting pulses follow these instructions
  - 1. Set Value of Register "00134" to the last 2 digits of the current year - Ex. 2012 = Register Value of "12"
  - 2. Set Value of Register "00135" to the current month using 2 places
     Ex. March = Register Value of "03" November = Register Value of "11"
  - 3. Set Value of Register "00136" to the current day using 2 places
    Ex. 5th = Register Value of "05"
    28th = Register Value of "28"
  - 4. Set Value of Register "00137" to the current Hour using 2 places
    Ex. 8:00 am = Register Value of "08"
    8:00 pm = Register Value of "20"
  - 5. Set Value of Register "00138" to the current Minute using 2 places
     Ex. 0:07 = Register Value of "07"
    0:24 = Register Value of "24"
- 10. To save your information simply click the Button (or select Save As from the File Menu) and select the directory in which to save your file

Save As		-
OO + Libraries + Documents +	+ ++ Search D	ocuments
Organize - New folder		· · · · · · · · · · · · · · · · · · ·
Documents library Includes: 2 locations	Arrange	by: Folder -
Name	Date modified	Type
My Google Gadgets	7/13/2011 3:18 PM	File fold
My Music	7/13/2011 2:32 PM	File fold
My Music	7/14/2009 1:08 PM	File fold
My Palettes	3/14/2012 8:16 PM	File fold
My Pictures	7/13/2011 2:32 PM	File fold
My Pictures	7/14/2009 1:08 PM	File fold
My Received Files	8/5/2011 1:38 AM	File Told
C ALACTER II	3/12/04/1 2020/04	
File name: Minus File		
Save as type: Modbus Poll Files (*.mbp)		

- 11. To clear the Range Registers (00118-00119), Right-Click Register "00134"
  - Set the "Value" to any single Integer (1-999)
    - This will subsequently, also act as the creation of a new testing file